# Solar Ready Provisions - 2017 Oregon Residential Specialty Code
## Draft amendments

The amendments are depicted as follows:

- ~~Strikethrough~~ text represents deleted language.
- Underlined text represents added language.

> **N1107.4 Solar ready.** ~~Reserved. This section will be updated with an interim amendment. See Oregon.gov/bcd.~~ A square metal junction box not less than 4 inches by 4 inches (102 mm by 102 mm) with a metal box cover shall be provided within 24 inches (610 mm) horizontally or vertically of the main electrical panel. A minimum ¾-inch metal raceway shall extend from the junction box to a capped roof termination or to an accessible location in the *attic* with a vertical clearance of not less than 36 inches (914 mm). Where the raceway terminates in the attic, the termination shall be located not less than 6 inches (152 mm) above the insulation. The end of the raceway shall be marked as "RESERVED FOR SOLAR."